

ASCE OXYGEN TRANSFER DETERMINATION

PROJECT: Otterbine
DATE: 26-Apr-07
RUN: 2

599 Waldron Rd.
 LaVergne, TN 37086
 615/793-7547
 FAX 615/793/5070

	Initial	Mid Point	Final		
Barometric Pres. (PSIA)	14.209	14.187	14.168		
(mm Hg)	734.80	733.70	732.70		
Ambient Temperature (°F)	65.80	67.60	73.60	C' Air Flow Rotometer	2.71
Relative Humidity (%)	64%	69%	59%	Air Flow Device 2 (SCFM)	12.33
Line Pressure (PSIG)	14.205	14.205	14.205	TDS Water Density @ 20°C (kg/m³)	998.62
(In. Hg)	28.92	28.92	28.92	Standard Density @ 20°C (kg/m³)	998.23
Line Temperature (°F)	105.00	111.00	116.00	Temp. Correction Factor (τ)	1.07
				Pressure Correction Factor (Ω)	0.97
Rotometer (SCFH)	425.000	415.000	412.000	Average Air Flow (SCFM)	12.33
C _{sm} T (Standard Methods, mg/l at 0 TDS)		9.713	β (C _{20TDS} /C _{20CW})	Effective Depth Correction (f)	0.35
C* ₂₀ (mg/L at 0 TDS)		11.901	0.997	Headloss (In. H ₂ O)	39.21
Water Temp. (°C)	16.53	16.68	17.07	C* (mg/l)	12.33
Orifice Diameter (in)		NA		C _{sm} T (Standard Methods, mg/l at test TDS)	9.68
Number Of Aeration Devices		12		C* ₂₀ (mg/L at Test TDS)	11.86
Side Water Depth (ft)		30.00	(9.14 m)	Tank Volume (Ft³)	10,390.8
Air Release Depth (ft)		29.50	(8.99 m)	(Gallons)	77,728.7
Tank Length (ft)		0.00	(0.00 m)	(m³)	294.2
Tank Width (ft)		0.00	(0.00 m)	(Million Pounds)	0.648
Tank Diameter (ft)		21.00	(6.40 m)	#Na ₂ SO ₃ @ 118% Stoichiometric	74.44
Gear Reducer or Belt Efficiency		100.0%		Cobalt Concn. (mg/l)	0.100
Motor Efficiency		85.0%		Grams Cobalt Chloride	121.3
Viscosity at 20° (μ - cp)		1.002		Viscosity at Test Temperature & Pressure (μ - cp)	1.086
				Effective Saturation Depth (d _e)	10.29
Blower HP _{wire}		1.64	(1.22 kw)	Blower HP _{motor}	1.39
Total HP _{wire} av.		1.64	(1.22 kw)	Total HP _{motor} av.	1.39
Actual Air Flow (ACFM)		6.96		TDS (mg/L)	504.00

NON-LINEAR REGRESSION RESULTS

Probe	K _{LaT}	K _{La20}	SOTR	SOTR/Dev	SOTE	SAE _{wire}	C*	Std. Err.
1	0.40	0.44	3.34	0.28	26.13	2.04	12.26	0.0468
2	0.40	0.43	3.34	0.28	26.13	2.04	12.29	0.0222
3	0.40	0.43	3.34	0.28	26.14	2.04	12.39	0.0314
4	0.40	0.43	3.35	0.28	26.22	2.05	12.51	0.0269
5	0.42	0.45	3.45	0.29	27.02	2.11	12.19	0.2340
NA	NA	NA	NA	NA	NA	NA	NA	NA
avg.	0.40	0.44	3.36	0.28	26.33	2.06	12.33	0.0723
Avg	0.40	0.43	3.34	0.28	26.13	2.04	12.31	Exclude Max&Min
TDS	0.42	0.46	3.53	0.29	27.62	2.16	12.33	0.94%
	/hr	/hr	#O ₂ /hr		%	#O ₂ /hr-WHP		

OXYGEN TRANSFER									
Total SCFM:	12.3	19.820	:Nm ³ /Hr	5.818	L/s	#O ₂ /Hr:	3.36	1.523	:KgO ₂ /Hr
SCFM/Diff.:	1.03	1.652	:Nm ³ /hr/Diff			#O ₂ /Hr/Diff.:	0.28	0.127	:KgO ₂ /Hr/Diff.
SCFM/KCF:	1.2	0.067	:Nm ³ /hr/m ³			#O ₂ /Day:	80.6	36.6	:KgO ₂ /Day
Total ICFM:	12.8	6.04	L/s			#O ₂ /Day/1000 Ft ³ :	8	0.12	:KgO ₂ /Day/m ³

LINEAR REGRESSION RESULTS

Probe	K _{LaT}	K _{La20}	SOTR	SOTR/Dev	SOTE	SAE _{wire}	C*	Corr.Coeff.
1	0.40	0.44	3.34	0.28	26.17	2.04	12.22	0.9993
2	0.41	0.44	3.37	0.28	26.36	2.06	12.26	0.9999
3	0.40	0.44	3.37	0.28	26.40	2.06	12.36	0.9998
4	0.40	0.43	3.36	0.28	26.31	2.05	12.48	0.9998
5	0.41	0.44	3.33	0.28	26.06	2.04	12.09	0.9866
NA	NA	NA	NA	NA	NA	NA	NA	NA
avg.	0.40	0.44	3.35	0.28	26.26	2.05	12.28	0.9971
Avg	0.41	0.44	3.39	0.28	26.55	2.07	12.28	Exclude Max&Min
TDS	0.42	0.46	3.55	0.30	27.77	2.17	12.28	
	/hr	/hr	#O ₂ /hr		%	#O ₂ /hr-HPW		